


# Certificate of Conformity

Certificate Number: CN-PVES-240067

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Shenzhen Eternalplanet Energy Pingshan Ltd. Room 220-3, Podium Building, Innovation Plaza, No. 2007, Pingshan Blvd, Liulian Community, Pingshan Subdistrict, Pingshan District, 518118 Shenzhen, Guangdong, China
<b>Product:</b>	Energy storage system
<b>Ratings &amp; Principle Characteristics:</b>	See appendix of Certificate of Conformity
<b>Model:</b>	EP Cube HES-EU1-706W; EP Cube HES-EU1-706G; EP Cube HES-EU1-710W; EP Cube HES-EU1-710G; EP Cube HES-EU1-713W; EP Cube HES-EU1-713G; EP Cube HES-EU1-716W; EP Cube HES-EU1-716G; EP Cube HES-EU1-720W; EP Cube HES-EU1-720G
<b>Brand Name&lt;s&gt;:</b>	 <b>ETERNALPLANET</b>
<b>Product Complies with:</b>	G99 Issue 1 Amendment 9, 3 October 2022
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai West Area, 2 <sup>nd</sup> Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
<b>Test Report No.&lt;s&gt;:</b>	2401B0617SHA-001

Additional information in Appendix.



Signature

Certification Manager: Qiao Qiao

Date: 27 February 2024



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-240067

### Ratings & Principle Characteristics:

Specifications table					
Model	EP Cube HES-EU1- 706W, EP Cube HES-EU1- 706G	EP Cube HES-EU1- 710W, EP Cube HES-EU1- 710G	EP Cube HES-EU1- 713W, EP Cube HES-EU1- 713G	EP Cube HES-EU1- 716W, EP Cube HES-EU1- 716G	EP Cube HES-EU1- 720W, EP Cube HES-EU1- 720G
PV terminal parameters					
Maximum PV voltage [V <sub>DC</sub> ]	600				
Rated voltage [V <sub>DC</sub> ]	360				
MPPT voltage range [V <sub>DC</sub> ]	90 - 550				
MPPT voltage range (full load) [V <sub>DC</sub> ]	312.5 - 450				
Maximum input current [A <sub>DC</sub> ]	16 per MPPT				
Isc PV [A <sub>DC</sub> ]	20 per MPPT				
MPPT tracker number	2				
Maximum input power [W]	10000				
Battery parameters					
Maximum voltage [V <sub>DC</sub> ]	87.6	131.4	175.2	219.0	262.8
Battery rated voltage [V <sub>DC</sub> ]	76.8	115.2	153.6	192	230.4
Battery voltage range [V <sub>DC</sub> ]	64.8~87.6	97.2~131.4	129.6~175.2	162.0~219	194.4~262.8
Maximum charge current [A <sub>DC</sub> ]	55				
Maximum discharge current [A <sub>DC</sub> ]	55				
Grid output terminal parameters					
Rated output voltage [V <sub>AC</sub> ]	230 Va.c., L+N+PE				
Rated output frequency [Hz]	50				
Rated output current [A <sub>AC</sub> ]	33				
Maximum continuous output current [A <sub>AC</sub> ]	33				
Rated output active power [W]	7600				
Maximum output active power [W]	7600				
Maximum output apparent power [VA]	7600				
Power factor range	0.8 under-excited to 0.8 over-excited				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.